

# Restraint for Ductile Iron Pipe or C900 PVC Pipe at Ductile Iron Fittings



Series 15PF06TD restraining both ductile iron pipe and C900 PVC pipe at a push-on fitting with restraining ears.





\*Tru-Dual Inserts are heat treated for hardness to ensure proper restraint on ductile iron pipe.

<sup>\*\*</sup>Two inserts are located near the clamp points on each half of the split serrated ring. This design provides maximum restraint on both ductile iron pipe and C900 PVC pipe enabling the product to be truly Tru-Dual.

			Pressure Ratings PSI					
			D.I. Pipe	C900 PVC Pipe				
Nominal Pipe Size	Series Number	Approx. Weight	DIP	DR14 Class 200	DR18 Class 150	DR25 Class 100		
4	15PF04TD	9.64	350	200	150	100		
6	15PF06TD	12.7	350	200	150	100		
8	15PF08TD	16.7	250	200	150	100		
10	15PF10TD	33.0	250	200	150	100		
12	15PF12TD	35.0	250	200	150	100		

NOTE: For applications or pressures not shown, please contact EBAA

De-rate pressure if not all connecting rods were used

### **Features and Applications:**


- Restraint for Ductile Iron Pipe at ductile iron fittings, meeting ANSI/AWWA C151/A21.51 and ANSI/AWWA C150/A21.50
- Restraint for AWWA C900 PVC Pipe at ductile iron fittings
- Minimum 2 to 1 Safety Factor
- MEGA-BOND® Restraint Coating System For more on MEGA-BOND refer to www.ebaa.com
- Constructed of ASTM A536 Ductile Iron


For use on water or wastewater pipelines subject to hydrostatic pressure and tested in accordance with either AWWA C600, C605, or ASTM D2774.

#### **Sample Specification**

Restraint for push on bells supplied with restraint ears on AWWA C900 PVC pipe and Ductile Iron pipe systems shall consist of the following: The restraint shall be manufactured of ductile iron conforming to ASTM A536. A split, serrated ring, with a sufficient number of heat treated Tru-Dual inserts for gripping both Ductile Iron Pipe and PVC pipe, shall be utilized to grip the pipe in conjunction with a sufficient number of bolts connecting the serrated restraint to the joint. The restraint devices shall be coated using MEGA-BOND®. (For complete specifications on MEGA-BOND visit www.ebaa.com.) The restraint for push on fittings shall be the Tru-Dual Series 15PF00TD; as manufactured by EBAA Iron, Inc., or approved equal.

1113-1.5-E Copyright © 2013 EBAA Iron, Inc





NOTE: Dimensions are in inches and are subject to change without notice.

**MADE IN USA** 

		A	В	С	D	*	Х
Nominal Pipe Size	Series Number	Pipe O.D.	Max Restraint O.D. (Casing Clearance)	Restraint Ring Width	Restraint Ring Location	Thrust Bolt Quantity	Thrust Bolt Circle (Min Max.)
4	15PF04TD	4.80	9.25	1.25	6	2	7.5
6	15PF06TD	6.90	11.25	1.63	6	2	9.5
8	15PF08TD	9.05	14.75	1.63	6	2	11.32 - 13.00
10	15PF10TD	11.10	16.85	2.15	6	4	13.48 - 14.94
12	15PF12TD	13.10	19.45	2.15	6	4	15.94 - 17.66

## **Installation Instructions**

for both C900 PVC Pipe and Ductile Iron Pipe



- 1. Identify the Pipe. The Series 15PF00TD 3. is designed for restraining C900 PVC pipe or Ductile Iron pipe at ductile iron fittings supplied with restraining ears. It has a split; serrated restraint ring with Tru-Dual® inserts on the spigot and attaches to the joint with connecting rods.
- 2. Assemble joint per the pipe manufacturer's instructions.



both halves of the restraint by tapping them into place. Allow enough room on the connecting rods to fully engage the nuts. Make sure the complete I.D. of the restraint is touching the pipe before installing and tightening of side bolts. Side bolts are to be evenly

the proper restraint location, install

tightened to 60 ft-lbs of torque (110 ftlbs on 8 inch, 10 inch, and 12 inch).



\*Derate pressure if not all connecting bolts were used.

Using the connecting rods to determine 4. Tighten the connecting bolts until snug. Do not over tighten connecting bolts as to move the spigot further into the joint.





# **EBAA IRON Sales, Inc.**

P.O. Box 857, Eastland, TX 76448 Tel: (254) 629-1731 Fax: (254) 629-8931 (800) 433-1716 within US and Canada contact@ebaa.com www.ebaa.com