

# **General Description**

The GENCUS2000 ceiling-mounted Ultrasonic Occupancy Sensor employs ultrasonic technology to accurately detect occupancy and automatically turn ON lighting. This low profile sensor is ideal for motion detection over partitions and other common obstructions. Once lighting has been turned ON, it employs ultrasonic technology to keep lighting ON while areas remain occupied. When the room or area is no longer occupied, the sensor turns OFF lighting after a preset time delay.

The low profile sensor is ceiling-mounted for greatest sensitivity to motion in large areas with obstructions. With a 360degree field of view and up to 2000 square feet of coverage area, the ceiling-mounted Ultrasonic Occupancy Sensor is ideal for conference rooms, classrooms, bathrooms, and large office areas.

These ceiling-mounted sensors also incorporate an integral light level sensor to prevent lighting from switching ON when sufficient ambient light is present, such as is commonly found in windowed areas.


Installation and configuration is simple. The sensor readily mounts to drop ceilings and features front located adjustments for setting sensitivity and time delay. The sensor also features an isolated relay for use with building automation and HVAC systems.


#### Features

- Oltrasonic motion detection
- Adjustable motion sensor sensitivity (45 to 100%)
- Ambient light level control system
- Adjustable light level control (0.5 to 250 fc (5.4 to 2691 lux))
- Adjustable delay OFF time (15 sec. to 20 min.)
- Turns the load ON manually if sensor has failed.
- 24VDC input
- EMS function: Isolated relay



# Ultrasonic Sensor Measurements






Major Motion

#### Illumination Range 0.5 to 250 footcandles (5.4 to 2691 lux) **Detection Area** 2000 square-feet (185 m<sup>2</sup>) 24VDC/AC Power Input **EMS** Output 1 x 1A @ 24VDC Resistive Current Consumption @ 24VDC 34 mA Nominal **Operating Temperature** 32 to 122°F (0 to 50°C) Maximum Humidity 90% RH Non-condensing Standard UL and cUL Listed Title 24 Certified

Project Name	
Project No.	

Date

### Specifications



dering Information			Authorised Distributor	
29187	GENCUS2000	Ceiling-Mounted Ultrasonic Occupancy Sensor	W. Co	
29189	GENPP1277	Power Pack 120/277	ADAPTABILITY IN LIGHTING CONTROL	
29190	GENPP1347	Power Pack 347		
29191	GENAUX24	Auxiliary Relay 120/277		
29192	GENAUX24347	Auxiliary Relay 347		
Part Number	Kameleon Model No.	Description		

