

ECS3 1-5 COMPACT LINE S0

DEUTSCH

Digitale Drehstrom-Energiezähler - COMPACT LINE Stromwandler - Anschluß (.../1 A oder .../5 A)



Table with columns: Code, Modell, Beschreibung. Lists models ECSEM222, ECSEM223MID and their specifications.

WARNUNG

Die Installation muß von einer Elektrofachkraft oder unter deren Leitung und Aufsicht durchgeführt und geprüft werden. Bei Arbeiten am Meßgerät, Netzspannung abschalten!

Main menu navigation guide for the meter. Lists various menu screens: Gerät einschalten, Zweite Wirkenergie (Abgabe) Seite, Dritte Wirkenergie (Bezug) Seite, etc.

Partial meter section (Partialzähler). Shows a display of 51065.13 and explains its function as a secondary meter for short-term energy control.


Energy Reset (Energie Reset) section. Explains how to reset the meter using the 'Menü' button and provides a visual of the 'rESEt P' screen.

Symbole section. Lists symbols for 3 measurement elements, backstop, and double insulation.

Display section. Shows the LCD display with indicators for active tariff (T8), connected phases (L1, L2, L3), and energy value (Partial).

Beschreibung der Tasten section. Describes the functions of the SET, Start, Menu, and Partial buttons.


Kabel-Abisolierlänge und max. Drehmoment der Klemmschraube section. Provides technical specifications for cable stripping length and screw torque.




MID geeicht section. Provides instructions for MID calibration, including terminal placement and sealing requirements.

Schaltbild

Der Energiezähler gehört zur ÜBERSpannungskategorie III (gemäß IEC 62052-31 der IEC-60664-1 Fassung 2.0:2007)...



Alternativer Schaltplan, (nicht zulässig für MID-Installation) mit nur 2 externen Stromwandlern. Nur bei folgenden Bedingungen verwenden...



- (1) Die Verbindung des Neutralleiters mit dem "N"-Anschluss an das Messgerät ist obligatorisch.
(2) Diese manuellen Trennschalter sind für eine sichere Installation obligatorisch.
(3) Diese Sicherungen sind nicht obligatorisch.
(4) Die Erdung von sekundären Wicklungen der Stromwandler wird durch die im Installationsland des Geräts geltenden Gesetze geregelt.

Technische Daten

Daten nach CLC/TR 50579 , EN 62059-32-1, EN 50470-1, EN 50470-3

Technical data table with columns: Allgemeine Daten, Funktion, Bemessungsparameter, Überlastbarkeit, Eigenschaft der Meßbereiche, Anzeigedaten. Includes values for DIN, mm, g, VAC, VA, Hz, etc.

DEUTSCH

Diagnosemeldungen section. Describes error messages: Ein oder mehrere fehlende Phase (missing phase), Phasenfolge Fehler (phase sequence error).


Fehleranzeige "Error" section. Explains the 'Error 02' or 'Error 3' display messages and their meanings.

Einstellbare Werte section. Details the 'PLEn' (impulse frequency limit) setting and how to adjust it.

Impulsausgang Einstellungen section. Provides instructions for setting the pulse output (T8) and its frequency.

Sekundär Wandlerstromregister Ablesung section. Explains how to read the secondary transformer current register.

Maße section. Provides dimensions for the meter unit, including height (45/90 mm) and width (72 mm).



Notizen

Notes table with columns for category, value, and unit. Lists environmental and safety notes like temperature range (-25...+70 °C) and protection class (IP51/IP40).

Herholdt Controls srl - 20132 Milano (Italy) contact information and logo.

Stand 10-06-2015

IST164-01

Three-phase Digital Energy meters - COMPACT LINE - CT connected (.../1 A or .../5 A)



Operating instructions
with partial active energy counter resettable

Code	Model	Description
ECSEM222	ECS3 1-5 CP	three-phases digital energy meter with connection by CT .../1 A up to 2000/1 A or by CT .../5 A up to 10.000/5 A 0.01-1(6) A - 2 tariffs - 2 S0 outputs
ECSEM223MID	ECS3 1-5 CP MID	same as above, with MID certification

WARNING
Installation must be carried out and inspected by a specialist or under his supervision. When working on the instrument, switch off the mains voltage!

Main Menu

Main Page: The value of the currently growing Active 3-phase Energy is represented (or the last one that has grown). The Energy is always Active, and may be Active Imported (right arrow), Active Exported (left arrow), with Tariff T1 or T2, depending on the current Energy flowing.

Second Active Energy Page

Third Active Energy Page

Fourth Energy Page: In the second, third and fourth pages the other 3 energy registers are represented

CT Primary Winding: In this page the primary winding of the CT appears. If the secondary winding is 5 A you can modify the value between 5 to 10000, otherwise if the secondary winding is 1 A you can modify the value between 1 to 2000.

CT Secondary Winding: In this page the CT secondary winding appears. You can choose between a secondary winding of 5 A or 1 A.

On-Time Page: In this page the On-time of the S0 pulse appears. The On-time can be adjusted between 30 ms and 100 ms.

Pulse Constant Page: In this page the number of pulses per kWh can be adjusted between 1 and maximum that depends on CT-ratio and on ON-time (see "Pulse rate limit" paragraph below)

Output Type Page: In this page the type of pulse outputs appears. You can select among:

- Pulse output 1: kWh imported
Pulse output 2: kWh exported
- Pulse output 1: kWh imported
Pulse output 2: kvarh imported
- Pulse output 1: kWh on tariff 1
Pulse output 2: kWh on tariff 2

Firmware Release Page: You can read the index of firmware release.

Firmware CheckSum Page: The checksum is periodically calculated to verify that the firmware is reliable.

Display Test Page: All the display segments are visible.

Whichever the page on the display, if no key is pushed for at least 20 sec., the main page appears again.

Partial counter


Partial Active Energy Counters: By pushing the "Partial key" partial active energy counters are readable in the main, second, third and fourth pages (i.e. for monthly energy consumption).

These counters are resettable. By pushing the "Partial key" in any of the four pages, you go back to the Main menu


Energy Reset

In all pages representing an Energy value, a pressure of 20 sec. of the "Menu key" allows to enter in the zeroing menu, consequently on the display "rESEt ?" appears. The key must be released. In order to confirm the operation and get back to default visualization, push it again for 4 seconds, otherwise after 4 sec., the reset will have no effect.
For model with MID certification only the partial Energy counters are resettable.

The Energy Meter has **OVERVOLTAGE CATEGORY III** (according to IEC 62052-31 that refers to IEC-60664-1 Ed. 2.0:2007), hence its direct connection to the Public Electricity Grid is not allowed. The Energy Meter is intended for INDOOR installation only (according to EN 50470-1 and IEC 62052-31). The Energy Meter must be installed on a DIN-rail and inside a cabinet with a protection degree (IP rating) equal to (or better than) IP51. Direct connection of currents inputs to the Energy Meter is NOT ALLOWED: external CTs insertion with proper insulation level are mandatory.



Alternative wiring diagram, (not allowed in MID installation) with only 2 external CTs. To be used only under the following conditions:
• The load is 3 wires (no neutral) and there is no current leakage (I1 - I2 - I3 = 0)
• Only 3-phase measures (Σ Power and Energies) are meaningful.



- The connection of the Neutral Wire to the "N" terminal of the Energy Meter is mandatory. Its connection to the Load is optional, but, in the case, only 3-phase measures (Powers and Energies) are meaningful, while measures referred to L1, L2, and L3 are meaningless.
- These manual disconnect switches are mandatory for safe installing operation. Their purpose and location must be easily evident to installation personnel
- These fuses are not mandatory, they are recommended to protect the line, not the device itself. Use >= 6 A fast (F) or >= 1 A delayed (T).
- Earthing of secondary windings of CTs is governed by the laws in force in the Countries where the device is installed. Current transformers must not be operated with open terminals since dangerous high voltages might occur which may result in personal injuries and property damage; furthermore, in this case the transformers are exposed to thermal overload.

Technical data

Data in compliance with CLC/TR 50579, EN 62059-32-1, EN 50470-1, EN 50470-3

		ENGLISH	
		ECSEM222 - ECSEM223MID CT connection	
		Pulse output S0	
General characteristics			
• Housing	DIN 43880	DIN	4 modules
• Mounting	EN 60715		35 mm DIN rail
• Depth		mm	70
• Weight		g	250
Operating features			
• Connection	to three-phase network	n° wires	4
• Storage of energy values and config.	Internal flash memory	-	yes
• Tariff	for active energy	n° 2	T1 and T2
Approval (according to EN 50470-1, EN 50470-3)			
• Type of connection		-	CT .../5 A or .../1 A
• Reference Voltage Un	Line to Neutral	VAC	230
• Reference Voltage Ull	Line to Line	VAC	400
• Reference Current (Iref)		A	1
• Minimum Current (Imin)		A	0.01
• Maximum Current (Imax)		A	6
• Starting Current (Ist)		A	0.001
• External CT	max. CT ratio	A	10.000/5 A or 2.000/1 A
	ratio adjusting step	A	5 or 1
		A	50
• Reference Frequency (fn)		A	50
• Number of phases (number of wires)		-	3 (4)
• Certified Measures		kWh	→ kWh T1, ← kWh T1 → kWh T2, ← kWh T2
• Accuracy	Active Energies (accor. to EN 50470-3) and Active Powers	class	B
Supply Voltage and Power Consumption			
• Operating Supply Voltage range		VAC	92 ... 276 / 160 ... 480
• Maximum Power Dissipation (Voltage circuit)		VA (W)	≤2 (0.6)
• Maximum VA burden (Current circuit) @ Imax		VA	≤0.7
• Voltage Input Waveform		-	AC
Overload capability			
• Voltage	continuous; phase/phase	VAC	480
	1 second; phase/phase	VAC	800
	continuous; phase/N	VAC	276
	1 second; phase/N	VAC	300
	continuous	A	6
	Temporary (0,5 ms)	A	120
• Current			
	continuous	A	6
	Temporary (0,5 ms)	A	120
Measuring Features			
• Voltage range	phase/phase	VAC	160 ... 480
	phase/N	VAC	92 ... 276
		A	0.001 ... 6
		Hz	45 ... 65
		-	kWh
• Current range (secondary winding)			
• Frequency range			
• Measured Quantities			
Display features			
• Display type	LCD	-	9 (2 Decimal)
	Energy digits dimension	mm	6 x 3
	min. ... max. kWh	mm	0.01 ... 9999999.99
		-	T1 or T2
		s	1
• Active Energy			
• Running Tariff			
• Display refresh period			
Optical metrological LED			
• Front mounted red LED (meter constant)	proportional to active imp/exp Energy	p/kWh	10000
Safety			
• Protective class		class	II
• AC voltage test (EN 50470-3, 7.2)		kV	4
• Degree of pollution		-	2
• Operational voltage		VAC	300
• Impulse voltage test		1.2/50 μs-kV	6
• Housing material flame resistance	UL 94	class	V0
• Safety-sealing between upper and lower housing part (mod. ECSEM223MID)		-	yes
Pulse Outputs (S0 signals)			
• Pulse Output 1	acc. to IEC 62053-31		kWh →, kWh ← / kvarh →, kvarh ← / kWh (T1) →, kWh (T2) →
• Pulse Output 2	adjustable		1 ... N (+)
• Pulse Rate	adjustable	p/kWh	(+/-) N - depends on CT-ratio and Pulse on Time
			30 ... 100
• Pulse ON-time	adjustable	ms	5 ... 33 VAC (5 ... 70 VDC)
• Operating Voltage	Min - Max	VAC (VDC)	90
• Pulse ON maximum current		mA	1
• Pulse OFF leakage current		μA	SELV circuit
• Isolation class		-	
Connection terminals			
• Screwdriver for mains terminals	head with Z +/-	POZIDRIV	P22
• Screwdriver for tariff and communication terminals	slotted head	mm	0.8 x 3.5
• Terminal capacity main current paths	solid wire min. (max)	mm²	1 (4)
	stranded wire with sleeve min. (max)	mm²	1 (4)
• Terminal capacity for tariff and communication	solid wire min. (max)	mm²	1 (4)
	stranded wire with sleeve min. (max)	mm²	1 (4)
Environmental conditions (storage)			
• Temperature range		°C	-25 ... +70
Environmental conditions (operating)			
• Temperature range		°C	-25 ... +55
• Mechanical environment		-	M1
• Electromagnetic environment		-	E2
• Installation	Indoor	-	yes
• Altitude (max.)		meters	≤2000
• Humidity	yearly average, not condensing	-	≤75%
	on 30 days per year (not condensing)	-	≤95%
• IP rating		-	IP51(*)/IP40

(*) For the installation in a cabinet at least with IP51 protection.

Note

Diagnostic Messages

One or more missing phase: In case one or more phase is not detected, the corresponding icon disappears from the bottom row of the display. E.G. L2 is not detected.

Phase sequence error: When the three phases are not in the correct zero-crossing sequence this message appears and the icons L1 and L2 blink. To make this message to disappear, you can keep pushed the "Menu key" for at least 4 seconds.

Error condition: When the display shows the message "Error 2 or Error 3", the meter has got a malfunction and must be replaced.

Editable values

In the main menu there are 3 values that you can modify: On-Time - Pulse Constant - Output Type
For example, in the On-Time page

Start (↖) key kept pushed for 4 seconds →

Push Start (↖) key to decrease, (↗) to increase. Push the "Menu key" to confirm, otherwise after 8 seconds the modification will be lost.

Pulse Rate Limit

The maximum number of pulses per kWh (Pulse constant) that the meter can generate through S0 outputs is limited by the CT ratio and by the ON time of the pulse. The relationship is:

$$\text{Max S0 Pulse Costant} = \frac{724368}{\text{CT ratio} \cdot (\text{ON time [msec]} + 30 \text{ msec})}$$

For example, if in your installation you need a CT ratio of 10000/5 = 200 and a ON pulse time of 70 ms, the maximum Pulse constant that you can select is:

$$\text{Max S0 Pulse Costant} (\text{CT ratio} = 200, \text{ON time} = 70 \text{ msec}) = \frac{724368}{200 \cdot (70 + 30)} \cong 36$$


You can always modify the CT ratio and the pulse ON time as you prefer; in case the Pulse Constant is too high for your selections, it is automatically adjusted to the maximum allowed value.

Secondary Winding Register Menu

On MID calibrated meters it's possible to show on display all energy registers measured at CT output (also via internal communication interface). For this, in any page of the "Main Menu", the "Menu key" must be pushed for 20 second. In this mode "⊙" appears and the meter shows the same page of the "Main Menu" but, in the first 4 pages, the energies are referred to the secondary winding of the CTs. After a minute of "Menu key" inactivity, the meter shows and communicates again the CT input energies.

Secondary winding register menu:

Dimension



Symbols

• Measuring elements

• Reversal preventing device

• Protected by double insulation

Display

• Energy value

• Tariff Running tariff, called tariff

• Energy line (L1-2-3)

• CT indicator

• Energy value "Partial"

• Precision control LED

Push - Buttons

• Parameters set

• Command button for "Partial" reading selection


• Menu key for reading selection

Cable stripping length and max terminal screw torque

1 A / 5 A CT connection main terminals
Screw driver PZ1

Tariff and communication terminals
Screw driver blade 0.8x3.5 mm

Sealable terminal covers



MID calibrated

A) Device code and certification data indications

B) Safety-sealing between upper and lower housing part