

1 DESCRIPTION

The BACnet^{®1} suite of drivers is designed to work with the FieldServer products. One or more drivers using different Data Link Layer options could be configured to act as a gateway between BACnet systems and RTU, SCADA's and PLC's using a wide variety of protocols. This document provides information relevant to the following FieldServer Drivers:

- FS-8700-16 BACnet PTP
- FS-8700-73 BACnet MS/TP
- FS-8704-06 BACnet/IP
- FS-8704-02 BACnet Ethernet

BACnet Vendor Name: Sierra Monitor Corporation
BACnet Vendor ID: 37

2 FORMAL DRIVER TYPE

The following Data Link layer options are supported:

- BACnet/IP, (Annex J)
- Point-to-Point, EIA 232 (Clause 10), baud rate up to 115 Kbps
- ISO 8802-3, Ethernet (Clause 7)
- MS/TP master (Clause 9), baud rate up to 38.4 Kbps
- MS/TP slave (Clause 9), baud rate up to 38.4 Kbps

Client or Server

3 CONNECTION INFORMATION

3.1 BACnet Ethernet

Connection Type: ISO 8802.3
Ethernet Speeds Supported: 10Base-T, 100Base-T

3.2 BACnet PTP

Connection Type: RS-232
Baud Rates: 9600, 19200, 38400, 76800
Data Bits: 7,8
Stop Bits: 1,2
Parity: Odd, Even, None
Multidrop Capability: No

3.3 BACnet MS/TP (Master and Slave Operation)

Connection Type: RS-485
(Two Wire, Half Duplex)
Baud Rates: 9600, 19200, 38400, 76800
Data Bits: 7,8
Stop Bits: 1,2
Parity: Odd, Even, None
Multidrop Capability: Yes

NOTE: When configured as a BACnet master, there is no physical limit to the number of remote BACnet slave devices is supported. When configured as BACnet slave, there is no physical limit to the number of virtual slave nodes supported. In both cases, the limitation is the point count capacity of the FieldServer.

3.4 BACnet/IP

Connection Type: Internet Protocol (IP)
Ethernet Speeds Supported: 10Base-T, 100Base-T
BBMD Supported: Yes (not supported on connections where FieldServer is a client)
Foreign Device Registration: Not supported for client connections

NOTE: When configured as a BACnet master, there is no physical limit to the number of remote BACnet slave devices is supported. When configured as BACnet slave, there is no physical limit to the number of virtual slave nodes supported. In both cases, the limitation is the point count capacity of the FieldServer.

¹ BACnet[®] is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE)

4 DEVICES TESTED

Device	Tested (FACTORY, SITE)
AutomatedLogic Corporation - S6104 Control Module MS/TP at 38400 Baud	FACTORY
Trane Company, BCU	SITE
Trane Company - Trace Summit Version 10,11,12,13	SITE
Alerton BTI	SITE
McQuay BACnet Gateway	SITE
York BACnet Gateway	SITE
Delta OWS	SITE
Reliable Controls Ethernet	SITE

5 DATA TYPES AND OPTIONAL PROPERTIES SUPPORTED

FieldServer Data Type	BACnet Object Type	Optional Properties Supported
AI	Analog Input Object	Reliability Description
AO	Analog Output Object	Reliability Description Max_Pres_Value Min_Pres_Value
AV	Analog Value Object	
BI	Binary Input Object	Reliability Description Active_Text Inactive_Text
BO	Binary Output Object	Reliability Description Active_Text Inactive_Text
BV	Binary Value Object	Reliability Description Active_Text Inactive_Text
MI	Multi-state Input Object	Reliability Description State_Text
MO	Multi-state Output Object	Reliability Description State_Text
MV	Multi-state Value Object	Reliability Description State_Text
Device	Device Object	Location Description UTC Offset Active COV Subscriptions
Trend Log		Description Log_Interval

6 FIELDSEVER AS A CLIENT

Read Operations Supported	Properties Supported	Comments and Limitations
Read Property	Present Value	Store value in Data Array location after scaling has been applied.
	Out_Of_Service	When using a Complex Data Object, the OOS property is fully supported. Return FALSE when not OOS or when using standard Data Arrays.
	Units	Returns Units as specified in the Map Descriptor.
	Reliability	When using a Complex Data Objects, returns "Unreliable Other" when the Node is offline, or when the data is old. Returns FALSE if the Node is online or when using Standard Data Arrays.
	Priority_Array	Returns Priority_Array of Map Descriptor.
	Unsupported	This property is supported.
	Protocol_Object_Type_Supported	This property is supported.
	Protocol_Services_Supported	This property is supported.
	Database_Revision	This property is supported and will change if a new configuration is downloaded to the FS.
	Max_Master	This Property is supported for the BACnet MS/TP DLL option.
	Max_Info_Frames	This Property is supported for the BACnet MS/TP DLL option.
	Relinquish_Default	Returns Relinquish_Default.
Read Property Multiple	As for Read Property	Transactions can be defined to read multiple objects and properties in a single ReadPropertyMultiple operation.
	ALL	Read Property Multiple of the ALL property is NOT supported.
Write Operations Supported	Properties Supported	Comments and Limitations
Write Property	Present Value	Send value in Data Array location after scaling has been applied.
Write Property Multiple		

7 FIELDSEVER AS A SERVER

7.1 Device Object

Read Operations Supported	Properties Supported	Comments and Limitations
Read Property	Object_Identifier	Returns Object_ID with Node_ID as Object Instance.
	Object_Name	Returns Node Name.
	Object_Type	Returns Device Object type.
	System_Status	Returns Normal.
	Vendor_Name	Returns FieldServer Technologies.
	Vendor_Identifier	Returns 37.
	Model_Name	Returns FieldServer model.
	Firmware_revision	Returns Kernel version.
	Application_sw_version	Returns DCC version.
	Protocol_Version	Returns version 1.
	Protocol_Revision	Returns revision 1.
	Protocol_Services_Supported	This property is supported.
	Protocol_Object_Type_Supported	This property is supported.
	Protocol_Object_List	Returns a list of objects defined in the FieldServer.
	Max_APDU_Length_Accepted	For FieldServers , the MAX APDU Length for BACnet MS/TP is 480 bytes and for BACnet/IP or BACnet Ethernet 1497 bytes. For ProtoCessors , the MAX APDU Length for BACnet MS/TP is 206 bytes and for BACnet/IP BACnet Ethernet 1497 bytes.
	Segmentation_Supported	Returns segmentation NOT supported.
	APDU_Timeout	Returns the value as defined by the Node's "Timeout" parameter.
	APDU_Retries.	Returns the value as defined by the Node's "Retries" parameter.

Read Property	Device_Address_Bindings	Returns an empty list.
	Max_Master	This Property is supported for the BACnet MS/TP DLL option.
	Max_Info_Frames	This Property is supported for the BACnet MS/TP DLL option.
	Description	This property is supported.
	Database_Revision	This property is supported and will change if a new configuration is downloaded to the FieldServer.
Read Property Multiple	Same properties as Read Property	Read Property Multiple is fully supported. Multiple objects with multiple properties can be specified.
Write Operations Supported	Properties Supported	Comments and Limitations
Write Property	Max_Master	This Property is supported for the BACnet MS/TP DLL option.
	Max_Info_Frames	This Property is supported for the BACnet MS/TP DLL option.
Write Property Multiple	Max_Master	This Property is supported for the BACnet MS/TP DLL option.
	Max_Info_Frames	This Property is supported for the BACnet MS/TP DLL option.

7.2 Analog Input Object

Read Operations Supported	Properties Supported	Comments and Limitations
Read Property	Object_Identifier	No limitations.
	Object_Name	Returns Map Descriptor Name.
	Object_Type	Returns Analog Input Object type.
	Present_Value	Returns value in Data_Array after scaling has been applied.
	Status_Flags	When using Complex Data Objects returns the FAULT and OUT_OF_SERVICE fields as indicated in the Reference Section of the BACnet specification. When using standard Data Arrays returns FALSE for all bits.
	Event_State	No limitations.
	Reliability	When using a Complex Data Objects, returns Unreliable Other when the Node is offline, or when the data is old. Returns FALSE if the Node is online or when using Standard Data Arrays.
	Out_Of_Service	Fully supported when using a Complex Data Object. Returns FALSE when not OOS or when using standard Data Arrays.
	Description	This property is supported.
	Units	Returns Units as specified in the Map Descriptor.
Read Property Multiple	Same properties as Read Property	Read Property Multiple is fully supported. Multiple objects with multiple properties can be specified.
Write Operations Supported	Properties Supported	Comments and Limitations
Write Property	Present_Value	Writing to the Present Value is allowed if the Object is OOS.
Write Property Multiple		
Data Sharing Operations Supported	Properties Supported	Comments and Limitations
SubscribeCOV	Present_Value	Subscription storage is non-volatile.
COVNotification	Present_Value	Confirmed and Unconfirmed.
Alarm and Event Operations Supported	Properties Supported	Comments and Limitations
EventNotification	Present_Value, Status	Confirmed and Unconfirmed.
AcknowledgeAlarm		No limitations.

7.3 Analog Output Object and Analog Value Object

Read Operations Supported	Properties Supported	Comments and Limitations
Read Property	Object_Identifier	No limitations.
	Object_Name	Returns "Map Descriptor Name".
	Object_Type	Returns Analog Output Object type.
	Present_Value	Returns value in Data Array after scaling has been applied.
	Status_Flags	When using Complex Data Objects returns the FAULT and OUT_OF_SERVICE fields as indicated in the Reference Section of the BACnet specification. When using standard Data Arrays returns FALSE for all bits.
	Event_State	No limitations.
	Reliability	When using a Complex Data Objects, returns "Unreliable Other" when the Node is offline, or when the data is old. Returns FALSE if the Node is online or when using Standard Data Arrays.
	Out_Of_Service	Fully supported when using a Complex Data Object. Returns FALSE when not OOS or when using standard Data Arrays.
	Units	Returns Units as specified in the Map Descriptor.
	Priority_Array	Returns Priority_Array of Map Descriptor.
	Description	This property is supported.
	Relinquish_Default	Returns Relinquish_Default.
Read Property Multiple	Same properties as Read Property	Read Property Multiple is fully supported. Multiple objects with multiple properties can be specified.
Write Operations Supported	Properties Supported	Comments and Limitations
Write Property	Present_Value	When using Complex Data Objects and OOS is TRUE, then the write will not cause a write-through operation to the Server side. If the OOS is FALSE or when using standard Data Arrays then writes will always cause a write-through operation to the Server side.
Write Property Multiple		
Data Sharing Operations Supported	Properties Supported	Comments and Limitations
SubscribeCOV	Present_Value	Subscription storage is non-volatile.
COVNotification	Present_Value	Confirmed and Unconfirmed.
Alarm and Event Operations Supported	Properties Supported	Comments and Limitations
EventNotification	Present_Value, Status	Confirmed and Unconfirmed.
AcknowledgeAlarm		No limitations.

7.4 Binary Input Object

Read Operations Supported	Properties Supported	Comments and Limitations
Read Property	Object_Identifier	No limitations.
	Object_Name	Returns "Map Descriptor Name".
	Object_Type	Returns Analog Input Object type.
	Present_Value	Returns the binary value in the Data Array.
	Status_Flags	When using Complex Data Objects returns the FAULT and OUT_OF_SERVICE fields as indicated in the Reference Section of the BACnet specification. When using standard Data Arrays returns FALSE for all bits.
	Event_State	No limitations.
	Reliability	When using a Complex Data Objects, returns "Unreliable Other" when the Node is offline, or when the data is old. Returns FALSE if the Node is online or when using Standard Data Arrays.
	Out_Of_Service	Fully supported when using a Complex Data Object. Returns FALSE when not OOS or when using standard Data Arrays.

Read Property	Polarity	Always returns "Normal".
	Active_Text	Returns Active Text as specified on the Map Descriptor.
	Description	This property is supported.
	Inactive_Text	Returns Inactive Text as specified on the Map Descriptor.
Read Property Multiple	Same properties as Read Property	Read Property Multiple is fully supported. Multiple objects with multiple properties can be specified.
Write Operations Supported	Properties Supported	Comments and Limitations
Write Property	Present_Value	Writing to the Present Value is allowed if the Object is OOS.
Write Property Multiple		
Data Sharing Operations Supported	Properties Supported	Comments and Limitations
SubscribeCOV	Present_Value	Subscription storage is non-volatile.
COVNotification	Present_Value	Confirmed and Unconfirmed.
Alarm and Event Operations Supported	Properties Supported	Comments and Limitations
EventNotification	Present_Value, Status	Confirmed and Unconfirmed.
AcknowledgeAlarm		No limitations.

7.5 Binary Output Object and Binary Value Object

Read Operations Supported	Properties Supported	Comments and Limitations
Read Property	Object_Identifier	No limitations.
	Object_Name	Returns "Map Descriptor Name".
	Object_Type	Returns Analog Input Object type.
	Present_Value	Returns binary value in Data_Array.
	Status_Flags	When using Complex Data Objects returns the FAULT and OUT_OF_SERVICE fields as indicated in the Reference Section of the BACnet specification. When using standard Data Arrays returns FALSE for all bits.
	Event_State	No limitations.
	Reliability	When using a Complex Data Objects, returns "Unreliable Other" when the Node is offline, or when the data is old. Returns FALSE if the Node is online or when using Standard Data Arrays.
	Out_Of_Service	Fully supported when using a Complex Data Object. Returns FALSE when not OOS or when using standard Data Arrays.
	Priority_Array	Returns Priority_Array of Map Descriptor.
	Relinquish_Default	Returns current Relinquish_Default.
	Description	This property is supported.
	Active_Text	Returns Active Text as specified on the Map Descriptor.
	Inactive_Text	Returns Inactive Text as specified on the Map Descriptor.
Read Property Multiple	Same properties as Read Property	Read Property Multiple is fully supported. Multiple objects with multiple properties can be specified.
Write Operations Supported	Properties Supported	Comments and Limitations
Write Property	Present_Value	When using Complex Data Objects and OOS is TRUE, then the write will not cause a write-through operation to the downstream side. If the OOS is FALSE or when using standard Data Arrays then writes will always cause a write-through operation to the downstream side.
Write Property Multiple		
Data Sharing Operations Supported	Properties Supported	Comments and Limitations
SubscribeCOV	Present_Value	Subscription storage is non-volatile.
COVNotification	Present_Value	Confirmed and Unconfirmed.

Alarm and Event Operations Supported	Properties Supported	Comments and Limitations
EventNotification	Present_Value, Status	Confirmed and Unconfirmed.
AcknowledgeAlarm		No limitations.

7.6 Multiple State Input Object

Read Operations Supported	Properties Supported	Comments and Limitations
Read Property	Object_Identifier	No limitations.
	Object_Name	Returns "Map Descriptor Name".
	Object_Type	Returns Analog Input Object type.
	Present_Value	Returns unsigned integer value in the Data Array.
	Status_Flags	When using Complex Data Objects returns the FAULT and OUT_OF_SERVICE fields as indicated in the Reference Section of the BACnet specification. When using standard Data Arrays returns FALSE for all bits.
	Event_State	No limitations.
	Reliability	When using a Complex Data Objects, returns "Unreliable Other" when the Node is offline, or when the data is old. Returns FALSE if the Node is online or when using Standard Data Arrays.
	Description	This property is supported.
	Out_Of_Service	When using a Complex Data Object, the OOS property is fully supported. Return FALSE when not OOS or when using standard Data Arrays.
	Number_Of_State	When using a Complex Data Object, returns the number of states defined. When using Standard Data Arrays returns the value of 5.
	State_Text	When using Complex Data Objects returns the State Text strings defined. When using Standard Data Arrays, return "State_x" where "x" is the value stored in the Data_Array and could be 0 to 4.
Read Property Multiple	Same properties as Read Property	Read Property Multiple is fully supported. Multiple objects with multiple properties can be specified.
Write Operations Supported	Properties Supported	Comments and Limitations
Write Property	Present_Value	Writing to the Present Value is allowed if the Object is OOS.
Write Property Multiple		
Data Sharing Operations Supported	Properties Supported	Comments and Limitations
SubscribeCOV	Present_Value	Subscription storage is non-volatile.
COVNotification	Present_Value	Confirmed and Unconfirmed.
Alarm and Event Operations Supported	Properties Supported	Comments and Limitations
EventNotification	Present_Value, Status	Confirmed and Unconfirmed.
AcknowledgeAlarm		No limitations.

7.7 Multi-State Output Object and Multi-State Value Object

Read Operations Supported	Properties Supported	Comments and Limitations
Read Property	Object_Identifier	No limitations.
	Object_Name	Returns "Map Descriptor Name".
	Object_Type	Returns Analog Input Object type.
	Present_Value	Returns unsigned integer value in Data_Array.

Read Property	Status_Flags	When using Complex Data Objects returns the FAULT and OUT_OF_SERVICE fields as indicated in the Reference Section of the BACnet specification. When using standard Data Arrays returns FALSE for all bits.
	Event_State	No limitations.
	Reliability	When using a Complex Data Objects, returns "Unreliable Other" when the Node is offline, or when the data is old. Returns FALSE if the Node is online or when using Standard Data Arrays.
	Out_Of_Service	Fully supported when using a Complex Data Object. Returns FALSE when not OOS or when using standard Data Arrays.
	Number_Of_State	When using a Complex Data Object, returns the number of states defined. When using Standard Data Arrays returns the value of 5.
	State_Text	When using Complex Data Objects returns the defined State Text string. When using Standard Data Arrays, returns "State_x" where "x" is the value stored in the Data_Array and could be 0 to 4.
	Description	This property is supported.
	Priority_Array	Returns Priority_Array of Map Descriptor.
	Relinquish_Default	Returns Relinquish_Default.
Read Property Multiple	Same properties as Read Property	Read Property Multiple is fully supported. Multiple objects with multiple properties can be specified.
Write Operations Supported	Properties Supported	Comments and Limitations
Write Property	Present_Value	When using Complex Data Objects and OOS is FALSE or when using standard Data Arrays, writes will trigger a write-through operation to the Client side.
Write Property Multiple		
Data Sharing Operations Supported	Properties Supported	Comments and Limitations
SubscribeCOV	Present_Value	Subscription storage is non-volatile.
COVNotification	Present_Value	Confirmed and Unconfirmed.
Alarm and Event Operations Supported	Properties Supported	Comments and Limitations
EventNotification	Present_Value, Status	Confirmed and Unconfirmed.
AcknowledgeAlarm		No limitations.

7.8 Notification Class Object

Read Operations Supported	Properties Supported	Comments and Limitations
Read Property	Object_Identifier	No limitations.
	Object_Name	Returns "Map Descriptor Name".
	Object_Type	Returns Notification Class Object type.
	Description	No limitations.
	Notification_Class	No limitations.
	Priority	No limitations.
	Ack_Required	No limitations.
	Description	This property is supported.
	RecipientList	No limitations.
Read Property Multiple	Same properties as Read Property	Read Property Multiple is fully supported. Multiple objects with multiple properties can be specified.
Write Operations Supported	Properties Supported	Comments and Limitations
Write Property	Recipient_List	RecipientList Storage is non-volatile.
Write Property Multiple		
AddList	RecipientList	Used to subscribe to Alarm and Event Notifications.

8 UNSUPPORTED FUNCTIONS AND DATA TYPES

BACnet Object Type not Supported

Averaging Object
 Calendar Object
 Command Object
 Event Enrollment Object
 File Object
 Group Object
 Life Safety Point Object
 Life Safety Zone Object
 Loop Object
 Notification Class Object unsupported on Client side only
 Program Object
 Schedule Object

BACnet Services not Supported

Alarm and Event Services unsupported on Client side only
 File Access Services
 Virtual Terminal Services
 COV and EventNotification services are not supported for BACnet MS/TP on the ProtoCessor
 For BACnet MS/TP and PTP, COV services are disabled by default and may be enabled by setting the Node_Option property to COV_Enable in the Nodes section configuration file.