## CE-Declaration

Weinzierl Engineering GmbH Bahnhofstr. 6 DE-84558 Tyrlaching Tel. +49(0)8623 / 987 98 03 Fax +49(0)8623 / 987 98 09

E-Mail: info@weinzierl.de Web: www.weinzierl.de

This is to certify that

Product: KNX USB Interface 320

Version: Board

Manufacturer: Weinzierl Engineering GmbH, 84558 Tyrlaching, Germany

conforms to the following standards:

- Low voltage directive LVD 2006/95/EG
- Electromagnetic compatibility directive EMC 2004/108/EG
- Device fulfills EN 50090-2-2:2007 (HBES)
- Device fulfills EN 61000-6-2:2005 (Susceptibility)
- Device fulfills EN 61000-6-3:2007 (Emissions)

## **Intended use:**

This board is used to establish a connection between a PC and the installation bus EIB/KNX. It can be integrated into an existing system (industrial PC, ...). The USB connector has a galvanic separation from the EIB/KNX bus. The circuit is compatible with KNX medium TP1 (EIB), the firmware supports protocol EMI1.

Tyrlaching, January 29th 2008

Dr. Th. Weinzierl, CEO

T. Z.