

Weinzierl Engineering GmbH
Bahnhofstr. 6
DE-84558 Tyrlaching
Tel. +49(0)8623 / 987 98 03
Fax +49(0)8623 / 987 98 09
E-Mail: info@weinzierl.de
Web: www.weinzierl.de

CE-Declaration

This is to certify that

Product: **KNX ENO 610/612**
Version: Wall mounted box
Manufacturer: Weinzierl Engineering GmbH, 84558 Tyrlaching

conforms to the following standards:

- Low voltage directive 73/23/EWG, Edition 07/96
- EMC-Directive 89/336/EWG, Edition 02/96
- R&TTE Directive 1999/5/EC
- Device fulfills EN 50090-2-2 (ESHG) Edition 06/97
- Device fulfills EN 61000-6-2 (Susceptibility) Edition 10/2001
- Device fulfills EN 61000-6-3 (Emissions) Edition 10/2001
- Device fulfills EN 300 220-1: V2.1.1 and EN 300 220-2: V2.1.2 (SRD)

Intended use:

KNX ENO 610/612 acts as a gateway between EnOcean radio sensors and the KNX bus. It has 32 channels, each of which can be configured with one of the following functions: Switch module touch sensor, Temperature sensor, Window contact, Binary input, Light sensor and Motion detector

Tyrlaching, January 29th 2008



Dr. Th. Weinzierl, CEO