

Weinzierl Engineering GmbH  
Achatz 3  
DE-84508 Burgkirchen / Alz  
Tel. +49(0)8677 / 916 36 0  
Fax +49(0)8677 / 916 36 19  
E-Mail: info@weinzierl.de  
Web: www.weinzierl.de

## CE-Declaration

This is to certify that

Product: **KNX USB Interface 311**  
Version: REG  
Manufacturer: Weinzierl Engineering GmbH, 84508 Burgkirchen / Alz, Germany

conforms to the following standards:

Low voltage directive 2014 / 35 / EU  
EMC directive 2014 / 30 / EU  
RoHS directive 2011 / 65 / EU (RoHS2)  
EN 50491-3: 2009 (HBES, Electrical safety)  
EN 50491-5-1: 2010 (HBES, EMC General)  
EN 50491-5-2: 2010 (HBES, EMC Residential)  
EN 50491-5-3: 2010 (HBES, EMC Industrial area)  
EN 61000-6-2: 2005 (Immunity, Industrial area)  
EN 61000-6-3: 2007 + A1: 2011 (Emission, Residential)  
EN 50581: 2012 (RoHS2)

### Intended use:

This interface is for establish a bidirectional connection between a PC and the KNX installation bus. The device can be mounted on a DIN rail. The USB connector has a galvanic separation from the KNX bus. The device is compatible with KNX Medium TP and the firmware implements the EMI1 protocol.

Burgkirchen / Alz, April 18<sup>th</sup> 2016



Dr. Th. Weinzierl, CEO