

Weinzierl Engineering GmbH Achatz 3 DE-84508 Burgkirchen / Alz Tel. +49(0)8677 / 916 36 0 Fax +49(0)8677 / 916 36 19 E-Mail: info@weinzierl.de Web: www.weinzierl.de

## **CE-Declaration**

This is to certify that

Product:KNX IP LineMaster 762Version:REGManufacturer:Weinzierl Engineering GmbH, 84508 Burgkirchen / Alz, Germany

conforms to the following standards:

Low voltage directive 2014 / 35 / EU EMC directive 2014 / 30 / EU RoHS directive 2011 / 65 / EU (RoHS2) EN 50491-3: 2009 (HBES, Electrical safety) EN 50491-5-1: 2010 (HBES, EMC General) EN 50491-5-2: 2010 (HBES, EMC Residential) EN 50491-5-3: 2010 (HBES, EMC Industrial area) EN 61000-6-2: 2005 (Immunity, Industrial area) EN 61000-6-3: 2007 + A1: 2011 (Emission, Residential) EN 50581: 2012 (RoHS2)

## Intended use:

The KNX IP LineMaster 762 combines the essential functions of a KNX bus line: Power supply with choke, KNX IP Router and KNX IP Interface with a small footprint of only 6 units (108 mm).

The KNX IP Router in the LineMaster allows forwarding of telegrams between different lines through a LAN (IP) as a fast backbone. In addition this device is suited to connect a PC to the KNX network e.g. for ETS® programming.

Burgkirchen / Alz, December 14th 2016

T. Un

Dr. Th. Weinzierl, CEO