

Weinzierl Engineering GmbH Achatz 3 DE-84508 Burgkirchen / Alz Tel. +49(0)8677 / 916 36 0 Fax +49(0)8677 / 916 36 19 E-Mail: info@weinzierl.de Web: www.weinzierl.de

## **CE-Declaration**

This is to certify that

Product:KNX IP LineMaster 760Version:REGManufacturer:Weinzierl Engineering GmbH, 84508 Burgkirchen / Alz, Germany

conforms to the following standards:

- Low voltage directive LVD 2006 / 95 / EC
- EMC Directive 2004 / 108 / EC
- Conforms to EN 50491-5-1: 2010 (HBES, EMC General)
- Conforms to EN 50491-5-3: 2010 (HBES, EMC Industrial area)
- Conforms to EN 61000-6-2: 2005 (Immunity, Industrial area)
- Conforms to EN 61000-6-3: 2007 + A1: 2011 (Emission, Residential)
- Conforms to EN 61558-2-16: 2009

## Intended use:

The device is a combination of a power supply for a KNX line and a KNX IP router. The router part allows forwarding of telegrams between different KNX lines or areas (KNX medium TP) through Ethernet (IP) as backbone. In addition, it is for establishing a bidirectional connection between a PC and the KNX installation bus. The connection over IP conforms to KNX specification (KNXnet/IP).

Burgkirchen / Alz, Dec 1<sup>st</sup> 2014

T. Z

Dr. Th. Weinzierl, CEO